

Annual Drinking Water Quality and Compliance Report 2007

Ministry of Government Services Battleford District Care Centre Battleford, Saskatchewan

Introduction

The ministry of Environment requires that at least once each year waterworks owners provide notification to consumers of the quality of water produced and supplied as well as information on the performance of the waterworks in submitting samples as required by a **Minister's Order or Permit to Operate** a waterworks. The following is a summary of the **Battleford District Care Centre** water quality and sample submission compliance record for the **January 2007 to December 31, 2007** time period.

For more information on minimum sample submission requirements and the meaning of type of sample, please refer to "**Municipal Drinking Water Quality Monitoring Guidelines, November 2002, EPB 202**". Permit requirements for a specific waterworks may require more sampling than outlined in the department's monitoring guidelines. If consumers need more information on the nature and significance of specific water tests, for example, "**what is the significance of Selenium in a water supply**", more detailed information is available from: <http://www.hc-sc.gc.ca/hecs-sesc/water/dwgqsup.htm>.

The documentation in this report is based on site log books, Saskatchewan Provincial Laboratory and SRC Analytical Laboratories testing. Copies of all records are available on site or the contact information at the end of this report.

This report was completed on **April 1, 2008**.

Water Quality Standards

Bacteriological Quality:

Parameter/Location	Limit	Regular Samples Required	Regular Samples Submitted	# of Positive Regular Submitted (%)
Total Coliform	0 Organisms/100 mL	18	18	0 (0%)
Background Bacteria	Less than 200/100 mL			

Water Disinfection

Chlorine Residual in Distribution System for Test Results Submitted with Bacteriological Samples

Parameter	Minimum Limit	Free Chlorine Residual Range	Total Chlorine Residual Range	Average Free Chlorine (mg/L)	Average Total Chlorine (mg/L)
Chlorine	0.1 mg/L free		0.63 > 1.28	0.73	0.87
Residual	0.5 mg/L total	0.51 > 1.11			

Water Disinfection - Free Chlorine Residual for Water Entering Distribution System from Waterworks Records-From Water Treatment Plant Records

A minimum of 0.1 milligrams per litre (mg/L) free chlorine residual is required for water entering the distribution system. Tests are normally performed on a daily basis by the waterworks operator and are to be recorded in operation records. This data includes the number of free chlorine residual tests performed, the overall range of free chlorine residual (highest and lowest recorded values) and the number of tests and percentage of results not meeting the minimum requirement of 0.1 mg/L free chlorine residual.

Parameter	Limit (mg/L)	Test Level Range	# Tests Performed	# Tests Not Meeting Requirements
Free Chlorine Residual	> 0.1	0.03 > 1.43	364	5

Chemical Analysis

Health Category

All waterworks serving less than 5000 persons are required to submit water samples for Chemical Health category **once every two (2) years**. The Chemical Health category includes analysis for arsenic, barium, boron, cadmium, chromium, fluoride, lead, nitrate, selenium and uranium.

This waterworks receives treated water via a pipeline from the **Town of Battleford**. A Chemical analysis in the Health Category is not required to be performed on site. The Health Category analysis is performed by the **Town of Battleford** as per their **Permit to Operate a Waterworks**.

For further information please refer to the **Town of Battleford Annual Drinking Water Quality & Compliance Report**.

General Category

All waterworks serving less than 5000 persons are required to submit water samples for General Chemical category **once every two (2) years** if a ground water source. The General Chemical category includes analysis for alkalinity, bicarbonate, calcium, carbonate, chloride, conductivity, hardness (as CaCO₃), magnesium, sodium, sulphate and total dissolved solids.

This waterworks receives treated water via a pipeline from the **Town of Battleford**. A Chemical analysis in the General Category is not required to be performed on site. The General Category analysis is performed by the **Town of Battleford** as per their **Permit to Operate a Waterworks**.

For further information please refer to the **Town of Battleford Annual Drinking Water Quality & Compliance Report**.

More information on the water quality and sample submission performance may be obtained from:

Ministry of Government Services
2430 7th Avenue
Regina, Saskatchewan S4P 3V7
(306) 787-6332

Copies of this report are available at:

<https://watermon.spm.gov.sk.ca/>