

Annual Drinking Water Quality and Compliance Report

Saskatchewan Property Management Corporation Valley View Centre Moose Jaw, Saskatchewan

Introduction

Saskatchewan Environment (SE) requires that at least once each year waterworks owners provide notification to consumers of the quality of water produced and supplied as well as information on the performance of the waterworks in submitting samples as required by a *Minister's Order or Permit to Operate* a waterworks. The Saskatchewan Property Management Corporation owns and operates the waterworks at *Valley View Centre* in Moose Jaw. The following is a summary of the *Valley View Centre* water quality and sample submission compliance record for the *January 1, 2004 to December 31, 2004* time period. This report was completed on *January 10, 2005*.

For more information on minimum sample submission requirements and the meaning of type of sample, please refer to SE's "**Municipal Drinking Water Quality Monitoring Guidelines, November 2002, EPB 202**". Permit requirements for a specific waterworks may require more sampling than outlined in the department's monitoring guidelines. If consumers need more information on the nature and significance of specific water tests, for example, "*what is the significance of Selenium in a water supply*", more detailed information is available from:

<http://www.hc-sc.gc.ca/hecs-sesc/water/dwgsup.htm>.

Water Quality Standards

Bacteriological Quality:

Parameter/Location	Limit	Regular Samples Required	Regular Samples Submitted	# of Positive Regular Submitted (%)
Total Coliform	0 Organisms/100 mL	52	52	0 (0%)
Background Bacteria	Less than 200/100 mL			0 (0%)

Water Disinfection – Chlorine Residual in Distribution System for Test Results Submitted with Bacteriological Samples

Parameter	Minimum Limit	Free Chlorine Residual Range	Total Chlorine Residual Range	# Tests with Improper Data	# Tests with Inadequate Chlorine (%)
Chlorine Residual	0.1 mg/L free				
	0.5 mg/L total	0.28 – 1.63	.57 > 1.79	0	0 (0%)

Water Disinfection - Free Chlorine Residual for Water Entering Distribution System from Waterworks Records-From Water Treatment Plant Records

Parameter	Limit (mg/L)	Test Level Range	# Tests Performed	# Tests Not Meeting Requirements
Free Chlorine Residual	at least 0.1	.03 > 1.68	359	7

A minimum of 0.1 milligrams per litre (mg/L) free chlorine residual is required for water entering the distribution system. Tests are normally performed on a daily basis by the waterworks operator and are to be recorded in operation records. This data includes the number of free chlorine residual tests performed, the overall range of free chlorine residual (highest and lowest recorded values) and the number of tests and percentage of results not meeting the minimum requirement of 0.1 mg/L free chlorine residual.

Chemical -Trihalomethanes

Parameter	Limit IMAC (ug/L)	Sample Result (average)	# Samples Required	# Sample Submitted
Trihalomethanes (THMs)	100	71	4	4

THMs are generated during the water disinfection process as a by-product of reactions between chlorine and organic material. THMs are generally found only in drinking water obtained from surface water supplies. THMs are to be monitored on a quarterly basis and the IMAC result is expressed as an average of 4 quarterly samples. Only water supplies derived from surface water or groundwater under the influence of surface water are required to monitor for THMs.

Chemical – Health Category

All waterworks serving less than 5000 persons are required to submit water samples for SE's Chemical Health category **once every two (2) years**. The Chemical Health category includes analysis for arsenic, barium, boron, cadmium, chromium, fluoride, lead, nitrate, selenium and uranium.

All water for the **Valley View Centre Waterworks** is supplied by the City of Moose Jaw and the Buffalo Pound Treatment Plant. For Chemical Health analysis, please refer to the Buffalo Pound Water Administration Board 2003 Annual Report. It can be found at the City of Moose Jaw website at:

<http://www.citymoosejaw.com/departments/engineers/municipal/waterquality.shtml>

Sample results indicated that the provincial drinking water quality standards were not exceeded.

General Chemical

All waterworks serving less than 5000 persons are required to submit water samples for SE's General Chemical category **once every two (2) years** if a ground water source. The General Chemical category includes analysis for alkalinity, bicarbonate, calcium, carbonate, chloride, conductivity, hardness (as CaCO₃), magnesium, sodium, sulphate and total dissolved solids.

All water for the **Valley View Centre Waterworks** is supplied by the City of Moose Jaw and the Buffalo Pound Treatment Plant. For General Health analysis, please refer to the Buffalo Pound Water Administration Board 2003 Annual Report. It can be found at the City of Moose Jaw website at:

<http://www.citymoosejaw.com/departments/engineers/municipal/waterquality.shtml>

If consumers need more information on the nature and significance of specific water tests, for example, "**what is the significance of Selenium in a water supply**", more detailed information is available from:

<http://www.hc-sc.gc.ca/hecs-sesc/water/dwgsup.htm>

More information on water quality and sample submission performance may be obtained from:

**Saskatchewan Property Management Corporation
Accommodation Services Division
Infrastructure Support Services
Regina, Saskatchewan
(306) 787-6332**