

Annual Drinking Water Quality and Compliance Report

Saskatchewan Property Management Corporation Whitespruce Centre Yorkton, Saskatchewan

Introduction

Saskatchewan Environment (SE) requires that at least once each year waterworks owners provide notification to consumers of the quality of water produced and supplied as well as information on the performance of the waterworks in submitting samples as required by a **Minister's Order or Permit to Operate** a waterworks. The following is a summary of the **Whitespruce Centre** water quality and sample submission compliance record for the **January 2004 to December 31, 2004** time period.

For more information on minimum sample submission requirements and the meaning of type of sample, please refer to SE's "**Municipal Drinking Water Quality Monitoring Guidelines, November 2002, EPB 202**". Permit requirements for a specific waterworks may require more sampling than outlined in the department's monitoring guidelines. If consumers need more information on the nature and significance of specific water tests, for example, "**what is the significance of Selenium in a water supply**", more detailed information is available from: <http://www.hc-sc.gc.ca/hecs-sesc/water/dwqsup.htm>.

The documentation in this report is based on site log books, Saskatchewan Provincial Laboratory and SRC Analytical Laboratories testing. Copies of all records are available on site or the contact information at the end of this report..

This report was completed on **January 3, 2005**.

Water Quality Standards

Bacteriological Quality:

Parameter/Location	Limit	Regular Samples Required	Regular Samples Submitted	# of Positive Regular Submitted (%)
Total Coliform	0 Organisms/100 mL	12	12	0 (0%)
Background Bacteria	Less than 200/100 mL	12	12	0 (0%)

Water Disinfection

Chlorine Residual in Distribution System for Test Results Submitted with Bacteriological Samples

Parameter	Minimum Limit	Total Chlorine Residual Range	Free Chlorine Residual Range	# Tests Required	# Tests Submitted	# Adequate Chlorine (%)
Chlorine Residual	0.1 mg/L free 0.5 mg/L total	0.25 > 0.92	0.14 > 0.72	12	12	12 (100%)

Water Disinfection - Free Chlorine Residual for Water Entering Distribution System from Waterworks Records-From Water Treatment Plant Records

A minimum of 0.1 milligrams per litre (mg/L) free chlorine residual is required for water entering the distribution system. Tests are normally performed on a daily basis by the waterworks operator and are to be recorded in operation records. This data includes the number of free chlorine residual tests performed, the overall range of free chlorine residual (highest and lowest recorded values) and the number of tests and percentage of results not meeting the minimum requirement of 0.1 mg/L free chlorine residual.

Parameter	Limit (mg/L)	Test Level Range	# Tests Performed	# Tests Not Meeting Requirements
Free Chlorine Residual	> 0.1	0.49 > 1.08	366	0

Turbidity

Turbidity is an important indicator of water treatment process efficiency from both health and aesthetic perspectives. A waterworks producing water for human consumptive use is required to meet standards set out in its operating permit. A waterworks using groundwater and serving less than 5000 people must have a turbidity of less than 1.0 NTU.

From Water Treatment Plant Records

Parameter	Limit (NTU)	Test Level Range	# Tests Not Meeting Requirements	Maximum Turbidity (NTU)	# Tests Required	# Tests Performed
Turbidity	< 1.0	0.09 < 0.47	0	0.47	366	366

Chemical Analysis

Health Category

All waterworks serving less than 5000 persons are required to submit water samples for SE's Chemical Health category **once every two (2) years**. The Chemical Health category includes analysis for arsenic, barium, boron, cadmium, chromium, fluoride, lead, nitrate, selenium and uranium.

The last sample for Chemical Health analysis was required in **2004** and was submitted in **January 2004**. Sample results indicated that there was no exceedences to provincial drinking water quality standards.

Parameter	Limit MAC (mg/L)	Limit IMAC (mg/L)	Sample Result(s)	# Samples Exceeding Limit	
Arsenic		0.025	0.0009	0	* Results expressed as average values for communities or
Barium	1.000		0.1500	0	waterworks that
Boron		5.0	0.0300	0	fluoridate drinking
Cadmium	0.005		0.0005	0	water supplies or
Chromium	0.050		0.0050	0	those with elevated
Fluoride (avg*)	1.500		0.1400	0	concentrations of
Lead	0.010		0.0001	0	fluoride or nitrates.
Nitrate (avg.*)	45.000		1.0000	0	
Selenium	0.010		0.0002	0	
Uranium	0.020		0.0039	0	

General Category

All waterworks serving less than 5000 persons are required to submit water samples for SE's General Chemical category **once every two (2) years** if a ground water source. The General Chemical category includes analysis for alkalinity, bicarbonate, calcium, carbonate, chloride, conductivity, hardness (as CaCO_3), magnesium, sodium, sulphate and total dissolved solids.

The last sample for General Chemical analysis was required in **2004** and was submitted in **January, 2004**. Sample results indicated that there were no exceedences of the provincial aesthetic objectives for the General Chemical category.

Parameter	Aesthetic Objectives * (mg/L)	Sample Results (average)	# Samples Required	# Samples Submitted
Alkalinity	500	230.00	1	1
Bicarbonate	No Objective	281.00	1	1
Calcium	No Objective	68.00	1	1
Carbonate	No Objective	NT	0	0
Chloride	250	9.00	1	1
Conductivity	No Objective	538.00	1	1
Hardness	800	277.00	1	1
Magnesium	200	26.00	1	1
PH	No Objective	7.80	1	1
Sodium	300	8.00	1	1
Sulphate	500	53.00	1	1
Total dissolved Solids	1500	445.00	1	1

*Objectives apply to certain characteristics of or substances found in water for human consumptive or hygienic use. The presence of these substances will affect the acceptance of water by consumers and/or interfere with the practice of supplying good quality water. Compliance with drinking water aesthetic objectives is not mandatory as these objectives are in the range where they do not constitute a health hazards. The aesthetic objectives for several parameters (including hardness as CaCO_3 , magnesium, sodium and total dissolved solids) consider regional differences in drinking water sources and quality.

More information on the water quality and sample submission performance may be obtained from:

**Saskatchewan Property Management Corporation
2430 7th Avenue
Regina, Saskatchewan S4P 3V7
(306) 787-6332**